



- ① Y34-2 WOODFORD FROST PROOF YARD HYDRANT, OR APPROVED EQUAL
- ② 1" HEAVY DUTY GALV. STEEL PIPE STRAP SECURED TO POST WITH (2) 2½" GALV. WOOD SCREWS
- ③ 4x4 D.F. #2 OR BETTER ANCHOR POST, PT ACQ/CBA, OR APPROVED EQUAL
- ④ 4x4 GALV. STEEL OR ALUMINUM POST CAP
- ⑤ FINISH GRADE
- ⑥ 5/8" CRUSHED AGGREGATE PER WSDOT 9.039(3) COMPACTED TO 95% DENSITY, OR APPROVED EQUAL
- ⑦ 3/8" GRAVEL BACKFILL FOR DRAINS PER WSDOT 9-03.12 (4), OR APPROVED EQUAL
- ⑧ 3/4" BRASS CLOSE NIPPLE
- ⑨ 3/4" BRASS 90
- ⑩ 3/4" BRASS NIPPLE, LENGTH AS REQUIRED
- ⑪ X-3/4" BRASS BUSHING, SIZE AS REQUIRED
- ⑫ BRASS TEE OR 90, SIZE AS REQUIRED
- ⑬ SCH 40 PVC OR SDR 7 HDPE SUPPLY LINE, SIZE PER PLAN
- ⑭ COMPACT NATIVE MATERIAL



City of
Bellevue

TITLE:

IRRIGATION - FROST PROOF YARD HYDRANT

DRAWING #:	PK-IR-18
SCALE:	N.T.S.
REVISION DATE:	11-2020
DEPARTMENT:	PARKS