



- NOTES:**
1. CONCRETE SLAB TO BE 3000 PSI MIN. BROOMED FINISH WITH 4" SMOOTH BAND AROUND PERIMETER. INSTALL CUT JOINT EVERY 4'-0" O.C., TYP.
 2. 1 1/2" ABS DRAIN LINES SHALL BE SLIGHTLY SLOPED TOWARD THE CATCH BASIN AND DRY SUMP (OR SEWER) TO PROMOTE POSITIVE DRAINAGE.
 3. WASHED ROCK DRY SUMP SIDES, TOP AND BOTTOM SHALL BE LINED WITH FILTER FABRIC.
 4. PLUMB DRAIN TO SANITARY SEWER IF AVAILABLE IN LIEU OF DRY SUMP.
 5. INSTALL 1" WILKINS 600 SERIES PRESSURE REDUCING VALVE IF WATER PRESSURE EXCEEDS 75 PSI, TYP.



TITLE:
DRINKING FOUNTAIN INSTALLATION

DRAWING #:	PK-SF-04
SCALE:	N.T.S.
REVISION DATE:	12-2018
DEPARTMENT:	PARKS